

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Fri, 20 Oct 2017 15:05:21 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
9TH AVENUE VIADUCT WATER COOPERATIVE (Moose Jaw)	24-Nov-14	Precautionary Drinking Water Advisory for 9th Avenue Viaduct Co-operative Ltd.	1		Operational: Inadequate disinfection residual in distribution system Quality:
ABERDEEN WATERWORKS	19-Oct-17	PDWA Issued to Aberdeen (portion only) - water main break/depressurization	1		Operational: Treatment / distribution equipment failure or damage Quality: Line break or pressure loss in distribution system
ABERNETHY WATERWORKS	01-May-15	PDWA Issued to Abernethy - Does not meet minimum treatment	1		Operational: Does not meet minimum treatment/design requirements Quality: Cryptosporidium and/or Giardia detected in drinking water system

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Fri, 20 Oct 2017 15:05:21 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
ADAMS WATER CLUB WEST WATERWORKS-PIPELINE	24-Nov-14	PDWA ISSued to Adam's Water Club West due to Seasonal Low Chlorine Residual	1		Operational: Does not meet minimum treatment/design requirements Quality:
ALIDA WATERWORKS	25-Nov-11	ALIDA - PDWA - Seven service connections not receiving continuously disinfected water	1		Operational: Inadequate disinfection residual in distribution system Quality:
ALLAN	13-Oct-17	TOWN OF ALLAN, SK - PDWA, System depressurization due to planned maintenance	1		Operational: Planned system maintenance Quality: Line break or pressure loss in distribution system

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Fri, 20 Oct 2017 15:05:21 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
ALLAN	19-Oct-17	TOWN OF ALLAN, SK - PDWA, System depressurization due to power outage	1		Operational: Power outage resulting in system pressure loss or reduced storage of treated water Quality: Line break or pressure loss in distribution system
ALVENA	18-Oct-17	Village of Alvena PDWA - Issued due to depressurization caused by power outage	1		Operational: Power outage resulting in system pressure loss or reduced storage of treated water Quality: Line break or pressure loss in distribution system
ANTLER WATERWORKS	17-Nov-11	ANTLER: PDWA due to no certified operator and elevated THM's	1		Operational: No certified or adequately trained operator as required Quality:

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Fri, 20 Oct 2017 15:05:21 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
ATTONS LAKE REGIONAL PARK WATERWORKS	07-May-12	Attons Lake PDWA - Issued due to System Start Up / Lack of Treatment	1		Operational: Start up of waterworks Quality: Suspected contamination
BATTLEFORDS PROV.PK. WATERWORKS	04-Oct-17	Battlefords Prov Park PDWA - Issued due to lack of minimum disinfection	1		Operational: Inadequate disinfection residual in distribution system Quality:
BEAUVAL	14-Sep-17	NV of Beauval - Depressurization	1		Operational: Quality: Line break or pressure loss in distribution system

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Fri, 20 Oct 2017 15:05:21 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
Big Bear Camp	26-Sep-14	Big Bear Camp PDWA due to lack of minimum treatment requirements	1		Operational: Does not meet minimum treatment/design requirements Quality:
BLACKSTRAP PROV.PK. WATERWORKS	19-Oct-17	PDWA Issued to Blackstrap Prov Park due to inadequate chlorine residual in the distribution system	1		Operational: Inadequate disinfection residual in distribution system Quality: Exceedance of MAC or drinking water standard
BOGGY CREE WELLFIELD Affects two rural customers outside Regina	24-Jul-06	Boggy Creek Wellfield, two customers, PDWA due to well operations	1		Operational: Damaged well components Quality:

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Fri, 20 Oct 2017 15:05:21 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
Bridlewood Estates	15-Mar-16	PDWA - Bridlewood Estates - failure to have a certified operator	1		Operational: No certified or adequately trained operator as required Quality:
CANWOOD	17-Oct-17	Village of Canwood - PDWA for hydrant repair causing depressurization (portion only)	1		Operational: Planned system maintenance Quality: Line break or pressure loss in distribution system
CARIBOU SOUTH WATER USERS COOPERATIVE WATERWORKS-PIPELINE (Moose Jaw)	30-Nov-05	Caribou South Water Users Co-operative - PDWA - Inadequate Chlorine Residuals	1		Operational: Inadequate disinfection residual in distribution system Quality:

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Fri, 20 Oct 2017 15:05:21 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
CHURCHBRIDGE WATERWORKS	11-Oct-17	PDWA Issued - Town of Churchbridge (Portion Only) - Oct 11, 2017 @10am - Watermain Tie-in	1		Operational: Planned system maintenance Quality:
CLIMAX	18-Oct-17	Climax PDWA - Portion Only	1		Operational: Planned system maintenance Quality: Line break or pressure loss in distribution system
COPPER SANDS T.C. WATERWORKS	24-Jan-16	PDWA - Copper Sands Mobile Home Park - Depressurization	1		Operational: Does not meet minimum treatment/design requirements Quality: Line break or pressure loss in distribution system

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Fri, 20 Oct 2017 15:05:22 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
COTTONWOOD WATER USERS INC. WATERWORKS	30-Dec-13	PDWA Issued to the Cottonwood Water Users Inc. due to Seasonal Low Chlorine Residual	1		Operational: Inadequate disinfection residual in distribution system Quality:
CRAIK WATERWORKS	17-Aug-10	PDWA issued to the Town of Craik - Failing to meet Minimum Disinfection Levels (Ozone)	1		Operational: No or inadequate disinfection at the treatment plant Quality: Significant deterioration of source water quality suspected or confirmed due to environmental conditions
CREELMAN	11-Feb-17	VILLAGE OF CREELMAN, SK - PDWA, High turbidity off filters	1		Operational: Treatment unable to cope with significant deterioration in source water quality Quality: Unacceptable turbidity or particle counts in treated water

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Fri, 20 Oct 2017 15:05:22 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
CSW WATER CLUB WATERWORKS	04-Dec-14	PDWA - CSW Water Club - Low Chlorine Residual	1		Operational: Inadequate disinfection residual in distribution system Quality:
CUT KNIFE	28-Sep-17	Town of Cut Knife PDWA Orton St.	1		Operational: Quality: Line break or pressure loss in distribution system
DODSLAND	18-Oct-17	Village of Doddsland - PDWA due to extended power outage causing depressurization	1		Operational: Power outage resulting in system pressure loss or reduced storage of treated water Quality: Line break or pressure loss in distribution system

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Fri, 20 Oct 2017 15:05:22 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
DUNDURN RURAL WATER UTILITY WATERWORKS- PIPELINE	18-Oct-17	PDWA issued to Dundurn Rural Water Utility Phase 3 Line (Blackstrap Ext only) due to inadequate cl2	1		Operational: Inadequate disinfection residual in distribution system Quality: Exceedance of MAC or drinking water standard
ELROSE	18-Oct-17	Town of Elrose PDWA 4th Ave (portion)	1		Operational: Planned system maintenance Quality:
ELSTOW N. RURAL WATER UTILITY WATERWORKS	17-Sep-15	PDWA - Elstow N Rural Water Utility (amended) due to inadequate chlorine level in the dist. system	1		Operational: Inadequate disinfection residual in distribution system Quality: Exceedance of MAC or drinking water standard

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Fri, 20 Oct 2017 15:05:22 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
ENDEAVOUR WATERWORKS	19-Oct-17	Endeavour - PDWA	1		Operational: Power outage resulting in system pressure loss or reduced storage of treated water Quality: Line break or pressure loss in distribution system
ENGLEFELD	18-Oct-17	VILLAGE OF ENGLEFELD, SK - PDWA, System depressurization due to power outage	1		Operational: Power outage resulting in system pressure loss or reduced storage of treated water Quality: Line break or pressure loss in distribution system
FENWOOD WATERWORKS	29-Sep-11	PDWA Issued - Village of Fenwood - Effective 1pm Sept 29, 2011 - High Turbidity @ WTP and Low chlori	1		Operational: Inadequate disinfection residual in distribution system Quality:

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Fri, 20 Oct 2017 15:05:23 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
FRONTIER WATERWORKS	18-Oct-17	Frontier PDWA Power Outage	1		Operational: Power outage resulting in system pressure loss or reduced storage of treated water Quality:
GLADMAR	28-Feb-17	PDWA - Gladmar - failure to meet turbidity standards	1		Operational: Does not meet minimum treatment/design requirements Quality: Unacceptable turbidity or particle counts in treated water
GOOD SPIRIT PROV.PK. WATERWORKS	03-May-17	Good Spirit Provincial Park - Seasonal Start-Up PDWA	1		Operational: Start up of waterworks Quality: Insufficient Quantity

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Fri, 20 Oct 2017 15:05:23 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
GOODEVE WATERWORKS	16-Mar-17	PDWA Issued - Village of Goodeve - Mar 16, 2017 @ 11:30am - Lack of primary disinfection	1		Operational: Treatment unable to cope with significant deterioration in source water quality Quality:
GRANDVIEW BEACH WATERWORKS	02-Oct-17	PDWA Issued - Resort Village of Grandview Beach-Central Well due to Seasonal Operation	1		Operational: Does not meet monitoring requirements Quality:
HANLEY WATERWORKS	13-Mar-17	TOWN OF HANLEY, SK - PDWA, New system start-up	1		Operational: Start up of waterworks Quality:

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Fri, 20 Oct 2017 15:05:24 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
HAZLET	07-Dec-10	PDWA - Village of Hazlet - Elevated turbidity	1		Operational: Does not meet monitoring requirements Quality: Unacceptable turbidity or particle counts in treated water
HIGHWAY #1 WEST WATER CO-OP WATERWORKS-PIPELINE	30-Nov-05	Highway #1 West Water Co-operative - PDWA - Inadequate Chlorine Residuals	1		Operational: Inadequate disinfection residual in distribution system Quality:
HUBBARD WATERWORKS	16-Jan-16	PDWA Issued Village of Hubbard - Effective Jan 16, 2016 @9am - Equipment Failure	1		Operational: Treatment / distribution equipment failure or damage Quality:

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Fri, 20 Oct 2017 15:05:24 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
JEDBURGH	20-Sep-13	PDWA Issued - RM of Garry (Hamlet of Jedburgh) - Effective Spet 20, 2013 @1pm - High Turbidity and	1		Operational: Does not meet monitoring requirements Quality: Unacceptable turbidity or particle counts in treated water
KATEPWA RV PARK LTD. WATERWORKS	12-May-17	PDWA Issued - Katepwa RV Park - May 12, 2017@12pm - Seasonal Startup & Elevated Turbidity in Treated	1		Operational: Start up of waterworks Quality: Unacceptable turbidity or particle counts in treated water
KINCAID WATERWORKS	17-Oct-17	PDWA Issued - Village of Kincaid - Oct 17, 2017@11am - Pump failure / System depressurization	1		Operational: Treatment / distribution equipment failure or damage Quality:

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Fri, 20 Oct 2017 15:05:24 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
LA RONGE La Ronge Avenue from Backlund Street to Finlayson Street	23-Oct-17	NT of La Ronge (portion) PDWA - hydrant repairs	1		Operational: Quality: Line break or pressure loss in distribution system
LEADER	21-Oct-17	Leader PDWA 100 Blk 1st St. West	1		Operational: Planned system maintenance Quality:
LINTLAW WATERWORKS	19-Oct-17	Lintlaw - PDWA	1		Operational: Power outage resulting in system pressure loss or reduced storage of treated water Quality: Line break or pressure loss in distribution system

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Fri, 20 Oct 2017 15:05:24 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
MANKOTA	25-Oct-17	PDWA Issued to the Village of Mankota due to Planned System Maintenance	1		Operational: Planned system maintenance Quality: Line break or pressure loss in distribution system
MARKINCH	06-Sep-13	PDWA Issued to the Village of Markinch for Failing to Meet Minimum Treatment Requirements	1		Operational: Does not meet minimum treatment/design requirements Quality:
MEADOWLARK ESTATES WATERWORKS	29-Jan-15	PDWA to Meadowlark Estates - Amended due to low chlorine levels in the distribution system	1		Operational: Inadequate disinfection residual in distribution system Quality: Exceedance of MAC or drinking water standard

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Fri, 20 Oct 2017 15:05:24 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
MOOSOMIN	18-Feb-16	PDWA Issued - Town of Moosomin (Portion Only) North of HWY 1 - Can't maintain minimum chlorine resid	1		Operational: Inadequate disinfection residual in distribution system Quality:
MOUNT PLEASANT WATER PIPELINE WATERWORKS	05-Nov-14	Precautionary Drinking Water Advisory for Mount Pleasant Water Pipeline Corp.	1		Operational: Inadequate disinfection residual in distribution system Quality:
NEUDORF WATERWORKS	17-Oct-17	PDWA Issued - Village of Neudorf - Effective Oct 17, 2017 - Water main break/System Depressurization	1		Operational: Quality: Line break or pressure loss in distribution system

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Fri, 20 Oct 2017 15:05:24 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
NORTH VALLEY WATER LINE COOPERATIVE WATERWORKS -PIPELINE	08-Oct-09	PDWA for North Valley Waterline Cooperative - due to low chlorine residuals	1		Operational: Inadequate disinfection residual in distribution system Quality: Significant deterioration of source water quality suspected or confirmed due to environmental conditions
PLEASANTDALE WATERWORKS	29-Sep-17	Pleasantdale PDWA-Reservoir Cleaning	1		Operational: Planned system maintenance Quality: Line break or pressure loss in distribution system
PLUNKETT WATERWORKS	18-May-17	PDWA Issued - Village of Plunkett - Effective May 18, 2017 @5pm - Elevated Turbidity	1		Operational: Quality: Unacceptable turbidity or particle counts in treated water

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Fri, 20 Oct 2017 15:05:24 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
REDTHORPE UTILITY BOARD WATERWORKS	08-Feb-10	PDWA for Redthorpe Utility Board- low disinfection levels	1		Operational: Inadequate disinfection residual in distribution system Quality:
REDVERS WATERWORKS	21-Feb-06	Redvers PDWA - Only affects: Couture Motors, Real Wolensky, Prosper Tractor, Redvers Coop	1		Operational: Inadequate disinfection residual in distribution system Quality:
REGINA SOUTH PIPELINE PUBLIC UTILITY BOARD	06-Nov-06	Regina South Public Utility Board, PDWA start up, REVISED for low chlorine residuals	1		Operational: No or inadequate disinfection at the treatment plant Quality:

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Fri, 20 Oct 2017 15:05:24 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
Residents S. of Melfort on the Argi Can extension	17-Dec-04	Melfort - South of Melfort on the Agriculture Canada extension - PDWA - Low chlorination	1		Operational: Inadequate disinfection residual in distribution system Quality: Line break or pressure loss in distribution system
Resort Village of Candle Lake	15-Mar-16	RV of Candle Lake PDWA (failure to meet minimum treatment)	1		Operational: Does not meet minimum treatment/design requirements Quality:
RICHMOUND WATERWORKS	18-Oct-17	PDWA Issued - Village of Richmond - Effective Oct 18, 2017 @8am - Power outage & Depressurization	1		Operational: Power outage resulting in system pressure loss or reduced storage of treated water Quality:

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Fri, 20 Oct 2017 15:05:24 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
RM of Hoodoo Waterworks	01-Jun-17	RM of Hoodoo Cudworth and Wakaw water stations (outside reservoirs ONLY)	1		Operational: Quality: Suspected Contamination
RM OF WILTON INDUSTRIAL SUBDIVISION WATERWORKS	13-Oct-16	RM of Wilton Industrial Park PDWA Low Chlorine	1		Operational: Inadequate disinfection residual in distribution system Quality:
ROCHE PERCEE WATERWORKS	11-May-11	PDWA Issued - Village of Roche Percee - due to turbidity readings consistently greater than 1.0 NTU	1		Operational: Quality: Unacceptable turbidity or particle counts in treated water

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Fri, 20 Oct 2017 15:05:24 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
ROCKGLEN	15-Oct-17	PDWA Issued to the Town of Rockglen	1		Operational: Planned system maintenance Quality: Line break or pressure loss in distribution system
ROWANS RAVINE PROV.PK. WATERWORKS	02-Oct-17	PDWA Issued to Rowan's Ravine Provincial Park due to seasonal operation	1		Operational: Does not meet monitoring requirements Quality:
SANDY BAY WATERWORKS	21-Sep-17	Sandy Bay PDWA-System Depressurization Due to Power Outage	1		Operational: Power outage resulting in system pressure loss or reduced storage of treated water Quality: Line break or pressure loss in distribution system

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Fri, 20 Oct 2017 15:05:24 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
SASKATOON-SWC WATERWORKS	15-May-08	PDWA amended; SaskWater Saskatoon East and West Raw Water Lines (section only) -inadequate treatment	1		Operational: Does not meet minimum treatment/design requirements Quality:
SASKATOON-SWC WATERWORKS	19-Oct-17	PDWA Issued to SkWater S'toon W Tr Pipeline (N of Cory Potash Mine) - planned maint/depressurization	1		Operational: Planned system maintenance Quality: Line break or pressure loss in distribution system
SCEPTRE	18-Oct-17	Village of Sceptre PDWA Power Outage	1		Operational: Power outage resulting in system pressure loss or reduced storage of treated water Quality: Line break or pressure loss in distribution system

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Fri, 20 Oct 2017 15:05:24 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
SILTON WATERWORKS	14-Jun-13	PDWA Issued to the Village of Silton due to Elevated Turbidity	1		Operational: Does not meet minimum treatment/design requirements Quality: Unacceptable turbidity or particle counts in treated water
SMILEY WATERWORKS	18-Oct-17	Village of Smiley - PDWA due to extended power outage causing depressurization	1		Operational: Power outage resulting in system pressure loss or reduced storage of treated water Quality: Line break or pressure loss in distribution system
SPC-POPLAR RIVER POWER STN WATERWORKS	29-Jun-17	PDWA - SPC Poplar River Effective June 29, 2017 @ 0930 Planned Maintenance	1		Operational: Planned system maintenance Quality: Unacceptable turbidity or particle counts in treated water

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Fri, 20 Oct 2017 15:05:24 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
STENEN WATERWORKS	18-Oct-17	Stenen - PDWA	1		Operational: Power outage resulting in system pressure loss or reduced storage of treated water Quality: Line break or pressure loss in distribution system
STONY BEACH WATERWORKS	09-Dec-14	PDWA Issued to the Hamlet of Stony Beach due to Seasonal Low Chlorine Residual	1		Operational: Inadequate disinfection residual in distribution system Quality:
TOGO	18-Oct-17	Togo - PDWA	1		Operational: Power outage resulting in system pressure loss or reduced storage of treated water Quality: Line break or pressure loss in distribution system

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Fri, 20 Oct 2017 15:05:24 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
URANIUM CITY	11-Feb-15	Uranium City		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system
URANIUM CITY	30-May-01	PDWA - Uranium City - Lacks minimum water treatment processes	1		Operational: Does not meet minimum treatment/design requirements Quality:
YARBO	07-May-08	Yarbo, PDWA Higher than normal turbidity levels	1		Operational: Quality: Unacceptable turbidity or particle counts in treated water

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Fri, 20 Oct 2017 15:05:24 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
ZEALANDIA WATERWORKS	20-Apr-17	PDWA Issued to Zealandia due to elevated turbidity levels	1		Operational: Does not meet monitoring requirements Quality: Exceedance of MAC or drinking water standard
	19-Oct-17	SLLP-Sask Landing Subdivision PDWA	1		Operational: Planned system maintenance Quality:
	18-Oct-17	Leader PDWA 100 Blk 3rd St. West	1		Operational: Planned system maintenance Quality:

Totals: 83 1