

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Wed, 24 May 2017 17:16:44 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
9TH AVENUE VIADUCT WATER COOPERATIVE (Moose Jaw)	24-Nov-14	Precautionary Drinking Water Advisory for 9th Avenue Viaduct Co-operative Ltd.	1		Operational: Inadequate disinfection residual in distribution system Quality:
ABERNETHY WATERWORKS	01-May-15	PDWA Issued to Abernethy - Does not meet minimum treatment	1		Operational: Does not meet minimum treatment/design requirements Quality: Cryptosporidium and/or Giardia detected in drinking water system
ADAMS WATER CLUB WEST WATERWORKS-PIPELINE	24-Nov-14	PDWA ISSued to Adam's Water Club West due to Seasonal Low Chlorine Residual	1		Operational: Does not meet minimum treatment/design requirements Quality:

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Wed, 24 May 2017 17:16:44 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
ALIDA WATERWORKS	25-Nov-11	ALIDA - PDWA - Seven service connections not receiving continuously disinfected water	1		Operational: Inadequate disinfection residual in distribution system Quality:
ANTLER WATERWORKS	17-Nov-11	ANTLER: PDWA due to no certified operator and elevated THM's	1		Operational: No certified or adequately trained operator as required Quality:
ATTONS LAKE REGIONAL PARK WATERWORKS	07-May-12	Attons Lake PDWA - Issued due to System Start Up / Lack of Treatment	1		Operational: Start up of waterworks Quality: Suspected contamination

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Wed, 24 May 2017 17:16:44 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
BEAUVAL Amisk Street from Laliberte Avenue to Beaver Avenue, Beaver Avenue from Amisk Street to Ohoo Street	19-May-17	NV of Beauval (portion) PDWA - water main repairs	1		Operational: Quality: Line break or pressure loss in distribution system
Big Bear Camp	26-Sep-14	Big Bear Camp PDWA due to lack of minimum treatment requirements	1		Operational: Does not meet minimum treatment/design requirements Quality:
BOGGY CREE WELLFIELD Affects two rural customers outside Regina	24-Jul-06	Boggy Creek Wellfield, two customers, PDWA due to well operations	1		Operational: Damaged well components Quality:

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Wed, 24 May 2017 17:16:44 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
Bridlewood Estates	15-Mar-16	PDWA - Bridlewood Estates - failure to have a certified operator	1		Operational: No certified or adequately trained operator as required Quality:
CANDLE LAKE UTILITIES LTD. WATERWORKS	18-May-17	Candle Lake Utilities Seasonal PDWA (RV Park Only)	1		Operational: Start up of waterworks Quality:
CARIBOU SOUTH WATER USERS COOPERATIVE WATERWORKS-PIPELINE (Moose Jaw)	30-Nov-05	Caribou South Water Users Co-operative - PDWA - Inadequate Chlorine Residuals	1		Operational: Inadequate disinfection residual in distribution system Quality:

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Wed, 24 May 2017 17:16:44 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
COCHIN	16-May-17	Village of Cochin PDWA - Seasonal Lines - Issued due to system start up	1		Operational: Start up of waterworks Quality:
COPPER SANDS T.C. WATERWORKS	24-Jan-16	PDWA - Copper Sands Mobile Home Park - Depressurization	1		Operational: Does not meet minimum treatment/design requirements Quality: Line break or pressure loss in distribution system
COTTONWOOD WATER USERS INC. WATERWORKS	30-Dec-13	PDWA Issued to the Cottonwood Water Users Inc. due to Seasonal Low Chlorine Residual	1		Operational: Inadequate disinfection residual in distribution system Quality:

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Wed, 24 May 2017 17:16:44 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
CRAIK WATERWORKS	17-Aug-10	PDWA issued to the Town of Craik - Failing to meet Minimum Disinfection Levels (Ozone)	1		Operational: No or inadequate disinfection at the treatment plant Quality: Significant deterioration of source water quality suspected or confirmed due to environmental conditions
CREELMAN	11-Feb-17	VILLAGE OF CREELMAN, SK - PDWA, High turbidity off filters	1		Operational: Treatment unable to cope with significant deterioration in source water quality Quality: Unacceptable turbidity or particle counts in treated water
CSW WATER CLUB WATERWORKS	04-Dec-14	PDWA - CSW Water Club - Low Chlorine Residual	1		Operational: Inadequate disinfection residual in distribution system Quality:

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Wed, 24 May 2017 17:16:44 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
DUBUC WATERWORKS	21-May-17	PDWA Issued - Village of Dubuc - Effective May 21, 2017 @ 11:30am - Water main Break & Depressurizati	1		Operational: Quality: Line break or pressure loss in distribution system
EIGHT MILE PIPELINE ASSOCIATION WATERWORKS	05-Jan-17	PDWA for Eight Mile Pipeline Association	1		Operational: Inadequate disinfection residual in distribution system Quality:
ELSTOW N. RURAL WATER UTILITY WATERWORKS	17-Sep-15	PDWA Issued to Elstow N Rural Water Utility due to inadequate chlorine level in the dist. system	1		Operational: Inadequate disinfection residual in distribution system Quality: Exceedance of MAC or drinking water standard

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Wed, 24 May 2017 17:16:45 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
FENWOOD WATERWORKS	29-Sep-11	PDWA Issued - Village of Fenwood - Effective 1pm Sept 29, 2011 - High Turbidity @ WTP and Low chlori	1		Operational: Inadequate disinfection residual in distribution system Quality:
GLADMAR	28-Feb-17	PDWA - Gladmar - failure to meet turbidity standards	1		Operational: Does not meet minimum treatment/design requirements Quality: Unacceptable turbidity or particle counts in treated water
GOOD SPIRIT PROV.PK. WATERWORKS	03-May-17	Good Spirit Provincial Park - Seasonal Start-Up PDWA	1		Operational: Start up of waterworks Quality: Insufficient Quantity

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Wed, 24 May 2017 17:16:45 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
GOODEVE WATERWORKS	16-Mar-17	PDWA Issued - Village of Goodeve - Mar 16, 2017 @ 11:30am - Lack of primary disinfection	1		Operational: Treatment unable to cope with significant deterioration in source water quality Quality:
GREENWATER PROV.PK. WATERWORKS	05-May-17	Greenwater Lake Provincial Park Seasonal Startup PDWA	1		Operational: Quality:
Greig Lake Campground, Kimball Lake Campground, Murray Doell Campground, Sandy Beach Campground	08-May-17	Meadow Lake Provincial Park - seasonal start up PDWA's	1		Operational: Start up of waterworks Quality:

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Wed, 24 May 2017 17:16:45 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
HALBRITE WATERWORKS	12-May-17	VILLAGE OF HALBRITE, SK - PDWA, High Turbidity	1		Operational: Does not meet minimum treatment/design requirements Quality: Unacceptable turbidity or particle counts in treated water
HANLEY WATERWORKS	13-Mar-17	TOWN OF HANLEY, SK - PDWA, New system start-up	1		Operational: Start up of waterworks Quality:
HAZLET	07-Dec-10	PDWA - Village of Hazlet - Elevated turbidity	1		Operational: Does not meet monitoring requirements Quality: Unacceptable turbidity or particle counts in treated water

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Wed, 24 May 2017 17:16:45 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
HIGHWAY #1 WEST WATER CO-OP WATERWORKS- PIPELINE	30-Nov-05	Highway #1 West Water Co-operative - PDWA - Inadequate Chlorine Residuals	1		Operational: Inadequate disinfection residual in distribution system Quality:
HUBBARD WATERWORKS	16-Jan-16	PDWA Issued Village of Hubbard - Effective Jan 16, 2016 @9am - Equipment Failure	1		Operational: Treatment / distribution equipment failure or damage Quality:
INDIAN HEAD	27-Apr-17	TOWN OF INDIAN HEAD, SK - PDWA, System Depressurization	1		Operational: Treatment / distribution equipment failure or damage Quality: Line break or pressure loss in distribution system

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Wed, 24 May 2017 17:16:45 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
JEDBURGH	20-Sep-13	PDWA Issued - RM of Garry (Hamlet of Jedburgh) - Effective Spet 20, 2013 @1pm - High Turbidity and	1		Operational: Does not meet monitoring requirements Quality: Unacceptable turbidity or particle counts in treated water
KATEPWA RV PARK LTD. WATERWORKS	12-May-17	PDWA Issued - Katepwa RV Park - May 12, 2017@12pm - Seasonal Startup & Elevated Turbidity in Treated	1		Operational: Start up of waterworks Quality: Unacceptable turbidity or particle counts in treated water
KIPABISKAU REG.PK. WATERWORKS	11-May-17	Kipabiskau Regional Park PDWA-Startup of Seasonal System	1		Operational: Start up of waterworks Quality:

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Wed, 24 May 2017 17:16:45 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
LANCER	29-Jun-16	PDWA - Village of Lancer - June 29, 2016 - Elevated Turbidity	1		Operational: Does not meet monitoring requirements Quality: Unacceptable turbidity or particle counts in treated water
LEOVILLE WATERWORKS	15-May-17	Leoville PDWA	1		Operational: Quality: Line break or pressure loss in distribution system
MARKINCH	06-Sep-13	PDWA Issued to the Village of Markinch for Failing to Meet Minimum Treatment Requirements	1		Operational: Does not meet minimum treatment/design requirements Quality:

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Wed, 24 May 2017 17:16:45 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
MARQUIS RURAL WATER USERS WATERWORKS- PIPELINE	08-Mar-17	Planned PDWA for Marquis Rural Water Users Inc.	1		Operational: Planned system maintenance Quality: Line break or pressure loss in distribution system
MEADOWLARK ESTATES WATERWORKS	29-Jan-15	PDWA to Meadowlark Estates - Amended due to low chlorine levels in the distribution system	1		Operational: Inadequate disinfection residual in distribution system Quality: Exceedance of MAC or drinking water standard
MEETING LAKE REGIONAL PARK WATERWORKS	03-Jul-15	2015-07-03-Meeting Lake Regional Park PDWA	1		Operational: Inadequate disinfection residual in distribution system Quality: Exceedance of MAC or drinking water standard

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Wed, 24 May 2017 17:16:45 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
MOOSE JAW	27-Jul-16	PDWA - Portion of SE Moose Jaw - low disinfection residual	1		Operational: Inadequate disinfection residual in distribution system Quality: Significant deterioration of source water quality suspected or confirmed due to environmental conditions
MOOSOMIN	18-Feb-16	PDWA Issued - Town of Moosomin (Portion Only) North of HWY 1 - Can't maintain minimum chlorine resid	1		Operational: Inadequate disinfection residual in distribution system Quality:
MOOSOMIN & DISTRICT REGIONAL PARK WATERWORKS	02-May-17	PDWA Issued - Moosomin Regional Park - May 2,2017 @ 8am - Seasonal Start-up	1		Operational: Start up of waterworks Quality:

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Wed, 24 May 2017 17:16:45 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
MOUNT PLEASANT WATER PIPELINE WATERWORKS	05-Nov-14	Precautionary Drinking Water Advisory for Mount Pleasant Water Pipeline Corp.	1		Operational: Inadequate disinfection residual in distribution system Quality:
NORTH VALLEY WATER LINE COOPERATIVE WATERWORKS -PIPELINE	08-Oct-09	PDWA for North Valley Waterline Cooperative - due to low chlorine residuals	1		Operational: Inadequate disinfection residual in distribution system Quality: Significant deterioration of source water quality suspected or confirmed due to environmental conditions
PARKVIEW WATER USERS INC. WATERWORKS	12-Jan-17	Planned PDWA for Parkview Water Users Inc.	1		Operational: Planned system maintenance Quality: Line break or pressure loss in distribution system

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Wed, 24 May 2017 17:16:45 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
PLUNKETT WATERWORKS	18-May-17	PDWA Issued - Village of Plunkett - Effective May 18, 2017 @5pm - Elevated Turbidity	1		Operational: Quality: Unacceptable turbidity or particle counts in treated water
PRELATE	14-May-17	PDWA - Village of Prelate - May 14, 2017 - Water Treatment Plant Upgrades	1		Operational: Start up of waterworks Quality:
REDTHORPE UTILITY BOARD WATERWORKS	08-Feb-10	PDWA for Redthorpe Utility Board- low disinfection levels	1		Operational: Inadequate disinfection residual in distribution system Quality:

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Wed, 24 May 2017 17:16:45 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
REDVERS WATERWORKS	21-Feb-06	Redvers PDWA - Only affects: Couture Motors, Real Wolensky, Prosper Tractor, Redvers Coop	1		Operational: Inadequate disinfection residual in distribution system Quality:
REGINA SOUTH PIPELINE PUBLIC UTILITY BOARD	06-Nov-06	Regina South Public Utility Board, PDWA start up, REVISED for low chlorine residuals	1		Operational: No or inadequate disinfection at the treatment plant Quality:
Residents S. of Melfort on the Arji Can extension	17-Dec-04	Melfort - South of Melfort on the Agriculture Canada extension - PDWA - Low chlorination	1		Operational: Inadequate disinfection residual in distribution system Quality: Line break or pressure loss in distribution system

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Wed, 24 May 2017 17:16:45 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
Resort Village of Candle Lake	15-Mar-16	RV of Candle Lake PDWA (failure to meet minimum treatment)	1		Operational: Does not meet minimum treatment/design requirements Quality:
RM OF WILTON INDUSTRIAL SUBDIVISION WATERWORKS	13-Oct-16	RM of Wilton Industrial Park PDWA Low Chlorine	1		Operational: Inadequate disinfection residual in distribution system Quality:
ROCHE PERCEE WATERWORKS	11-May-11	PDWA Issued - Village of Roche Percee - due to turbidity readings consistently greater than 1.0 NTU	1		Operational: Quality: Unacceptable turbidity or particle counts in treated water

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Wed, 24 May 2017 17:16:45 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
ROSTHERN	11-May-17	PDWA Issued to Rosthern (1000 & 2000 Blks of 3rd St only) due to water main repair/depressurization	1		Operational: Treatment / distribution equipment failure or damage Quality: Line break or pressure loss in distribution system
ROWANS RAVINE PROV.PK. WATERWORKS	19-Sep-16	PDWA Issued to Rowan's Ravine Provincial Park - Effective Sept 19, 2016 for seasonal operation	1		Operational: Does not meet monitoring requirements Quality:
SASKATOON-SWC WATERWORKS	15-May-08	PDWA amended; SaskWater Saskatoon East and West Raw Water Lines (section only) -inadequate treatment	1		Operational: Does not meet minimum treatment/design requirements Quality:

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Wed, 24 May 2017 17:16:45 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
SASKATOON-SWC WATERWORKS	24-May-17	PDWA Issued to SaskWater Saskatoon NE Treated Pipeline (13 & 14 Setter's Ridge only) due to repairs	1		Operational: Treatment / distribution equipment failure or damage Quality: Line break or pressure loss in distribution system
SILTON WATERWORKS	14-Jun-13	PDWA Issued to the Village of Silton due to Elevated Turbidity	1		Operational: Does not meet minimum treatment/design requirements Quality: Unacceptable turbidity or particle counts in treated water
STONY BEACH WATERWORKS	09-Dec-14	PDWA Issued to the Hamlet of Stony Beach due to Seasonal Low Chlorine Residual	1		Operational: Inadequate disinfection residual in distribution system Quality:

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Wed, 24 May 2017 17:16:45 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
SUNNYSIDE COTT.OWN. WATERWORKS	23-May-17	2017-05-23-Sunnyside COA PDWA	1		Operational: Treatment / distribution equipment failure or damage Quality: Insufficient Quantity
URANIUM CITY	30-May-01	PDWA - Uranium City - Lacks minimum water treatment processes	1		Operational: Does not meet minimum treatment/design requirements Quality:
URANIUM CITY	11-Feb-15	Uranium City		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Wed, 24 May 2017 17:16:45 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
Wa Casa RV Park	19-May-17	Wa Casa RV Seasonal Start-up PDWA	1		Operational: Start up of waterworks Quality:
WEYBURN UTILITY BOARD WATERWORKS PIPELINE	12-May-17	PDWA - Weyburn Utility Board South Line - due to water line break	1		Operational: Quality: Line break or pressure loss in distribution system
WHITE CITY	23-May-17	TOWN OF WHITE CITY, SK - PDWA, System Depressurization	1		Operational: Planned system maintenance Quality: Line break or pressure loss in distribution system

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Wed, 24 May 2017 17:16:45 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
WOLLASTON LAKE WATERWORKS	17-May-17	2017-05-17 NS of Wollaston Lake PDWA	1		Operational: Inadequate disinfection residual in distribution system Quality: Unacceptable turbidity or particle counts in treated water
WROXTON WATERWORKS	16-Dec-14	PDWA Issued - Village of Wroxton - Effective Dec 16, 2014@10am - Elevated Turbidity	1		Operational: Quality: Unacceptable turbidity or particle counts in treated water
YARBO	07-May-08	Yarbo, PDWA Higher than normal turbidity levels	1		Operational: Quality: Unacceptable turbidity or particle counts in treated water

**Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO)
Currently in Effect for Waterworks that are Regulated by the Water Security Agency or Saskatchewan Ministry of Environment**

Wed, 24 May 2017 17:16:45 CDT

NOTICE: While Water Security Agency and Saskatchewan Ministry of Environment (Environment) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier, the Water Security Agency, or Environment as outlined on the site-specific PDWA or EBWO (see: http://www.saskh2o.ca/pdwa_ebwo.asp). If questions arise after hours regarding a PDWA or EBWO, a Water Security Agency or Environment Environmental Project Officer may be reached by calling 1-844-536-9494.

Community, system or area affected	Date Issued	Title	PDWA	EBWO	Comments
ZEALANDIA WATERWORKS	20-Apr-17	PDWA Issued to Zealandia due to elevated turbidity levels	1		Operational: Does not meet monitoring requirements Quality: Exceedance of MAC or drinking water standard
	15-May-17	Clearwater Lake Regional Park PDWA Seasonal Start-up	1		Operational: Start up of waterworks Quality:

Totals: 73 1