

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:34 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Airport Well - La Ronge [16588]	13-Feb-18 Mamawetan Churchill River Regional Health Authority	La Ronge Airport, Do Not Consume, 13Feb2018 high levels of chemical - PFOA and PFOS	1		Operational: Undetermined source of contamination Quality: Exceedance of MAC or drinking water standard
Angler Trail Resort Ltd. (Darsana Property) [22007]	11-Jun-09 Mamawetan Churchill River Regional Health Authority	PDWA for Angler Trail Resort Ltd. (Darsana Property) [22007]	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system
Approved Home of Shirley Cox - Hauled Water [13890] Approved Home of Shirley Cox - Hauled Water [13890]	22-Sep-16 Sunrise Regional Health Authority	PDWA - Approved Home of Shirley Cox Hauled Water [013890]	1		Operational: Quality: Total coliforms detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:34 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Athabasca Fishing Lodges - Engler Lake Lodge [15232]	01-Jul-07 Mamawetan Churchill River Regional Health Authority	EBWO for Athabasca Fishing Lodges - Engler Lake due to E.coli		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system
Bear's Camp [1100034] Bear's Camp [1100068]	29-Jul-16 Mamawetan Churchill River Regional Health Authority	Bear's Camp, PDWA, Total Coliforms Present	1		Operational: No or inadequate disinfection at the treatment plant Quality: Total coliforms detected in drinking water system
Besnard Lake Lodge [14552]	20-May-16 Mamawetan Churchill River Regional Health Authority	Besnard Lake Lodge, PDWA, Total Coliforms	1		Operational: No or inadequate disinfection at the treatment plant Quality: Total coliforms detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:34 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Black Bear Island Lodge [14691]	14-Jun-14 Mamawetan Churchill River Regional Health Authority	Black Bear Island Lodge		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system
Blue Willow Inn [5570]	07-Apr-16 Saskatoon Regional Health Authority	Blue Willow Inn #28893 Follow Up By GS April 6, 2016	1		Operational: Undetermined source of contamination Quality: Total coliforms detected in drinking water system
Blue Willow Inn [5570]	07-Apr-17 Saskatoon Regional Health Authority	EBWO Issued Blue Willow Inn Well (#28893)		1	Operational: Undetermined source of contamination Quality: E.coli detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:34 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Border City Petting Zoo Well [1179]	26-May-17 Prairie North Regional Health Authority	Border City Petting Zoo	1		Operational: Quality: Total coliforms detected in drinking water system
Burbidge Lake Lodge Ltd. [16531]	08-Jul-14 Mamawetan Churchill River Regional Health Authority	Burbidge Lake Lodge Ltd.	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system
Camp Can-Ta-Ka-Ye Well [20891]	25-May-12 Heartland Regional Health Authority	Camp Can-Ta-Ka-Ye PDWA	1		Operational: Does not meet minimum treatment/design requirements Quality: Unacceptable turbidity or particle counts in treated water

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:35 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Camp Kinisoo (1976) Ltd. [15315]	08-Jun-12 Mamawetan Churchill River Regional Health Authority	Camp Kinisoo (1976) Ltd.	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system
Camp Woodboia Well [11245]	30-Apr-18 Five Hills Regional Health Authority	PDWA Issued to Camp Woodboia	1		Operational: Start up of waterworks Quality:
Canadian	04-Jun-15 Mamawetan Churchill River Regional Health Authority	Canadian Wilderness Camp, PDWA, insufficient tmt & coliforms	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:35 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Cando Memorial Hall Well [24390]	09-Jul-14 Heartland Regional Health Authority	EBWO Cando Memorial Hall		1	Operational: Quality: E.coli detected in drinking water system
Cando School Well [15926]	10-Mar-17 Heartland Regional Health Authority	PDWA for the Cando School (Untreat portion of water system)	1		Operational: Does not meet minimum treatment/design requirements Quality: Total coliforms detected in drinking water system
Canora Beach Resort - Main Well [17155]	04-Sep-09 Sunrise Regional Health Authority	PDWA for Canora Beach Resort Public Water Supply [17155] due to the presence of coliform bacteria	1		Operational: Quality: Total coliforms detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:35 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Cheemo Lodge [15028]	07-Jul-14 Mamawetan Churchill River Regional Health Authority	Cheemo Lodge		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system
Churchill River Voyageur Lodge [15570]	24-Jun-11 Mamawetan Churchill River Regional Health Authority	EBWO Churchill River Voyager Lodge - upgraded from existing PDWA		1	Operational: Quality: E.coli detected in drinking water system
Churchill River Wilderness Camps [14673]	24-Jun-11 Mamawetan Churchill River Regional Health Authority	EBWO for Churchill River Wilderness Camp due to E.coli		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:35 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Coldwell Campground Public Water Supply [17154]	21-Jun-18 Heartland Regional Health Authority	Coldwell Recreation Site Campground PDWA	1		Operational: Does not meet minimum treatment/design requirements Quality: Total coliforms detected in drinking water system
Cornhusker Fishing Camp [15200]	25-Aug-14 Mamawetan Churchill River Regional Health Authority	Cornhusker Fishing Camp	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system
Cree Lake Lodge [15708]	25-Jun-10 Mamawetan Churchill River Regional Health Authority	PDWA for Cree Lake Lodge 2009 Ltd. due to total coliforms	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:35 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Cree River Lodge Inc. [15027]	13-Jul-17 Mamawetan Churchill River Regional Health Authority	PDWA Cree River Lodge Inc., 13jul2017, 23 Total Coliforms/100mL	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system
Crystal Lodge Inc. [15361]	28-Jun-10 Mamawetan Churchill River Regional Health Authority	EBWO - Crystal Lodge Ltd. Ispatamow Island, Cree Lake - existing PDWA amended to EBWO		1	Operational: Quality: Total coliforms detected in drinking water system
Danielson Visitor PW [16441]	06-Jun-18 Heartland Regional Health Authority	PDWA Danielson Prov Park Visitor Center	1		Operational: Does not meet minimum treatment/design requirements Quality: Line break or pressure loss in distribution system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:35 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Deception Lake Lodge [15772]	04-Jun-07 Mamawetan Churchill River Regional Health Authority	PDWA for Deception Lake Lodge due to total coliforms	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system
Drinking Falls Lodge [14696]	24-Jun-10 Mamawetan Churchill River Regional Health Authority	EBWO issued for Drinking Falls Lodge [14696]		1	Operational: No or inadequate disinfection at the treatment plant Quality:
Duck Pond Guest House (24091)	16-Apr-14	EBWO Issued for Duck Pond Guest House	1		Operational: Undetermined source of contamination
Duck Pond Guest House (24091)	Sunrise Regional Health Authority				Quality: E.coli detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:35 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Dyer Straits Campground Well [9872]	05-Sep-15 Regina Qu'Appelle Regional Health Authority	PDWA - Dyer Straits Campground Well	1		Operational: Undetermined source of contamination Quality: Total coliforms detected in drinking water system
Elaine Lake Outfitting [21857]	14-Jun-13 Mamawetan Churchill River Regional Health Authority	Elaine Lake Outfitting	1		Operational: Non-commissioned plant Quality: Total coliforms detected in drinking water system
Elbow Lutheran Bible Camp Well [11299]	30-Apr-18 Five Hills Regional Health Authority	PDWA Issued to Elbow Lutheran Bible Camp	1		Operational: Start up of waterworks Quality:

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:35 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Ena Lake Lodge [15024]	04-Jul-07 Mamawetan Churchill River Regional Health Authority	PDWA for Ena Lake Lodge due to total coliforms	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system
Errington Lake Outfitters [15567]	28-Jun-14 Mamawetan Churchill River Regional Health Authority	Errington Lake Outfitters	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system
Eston Regional Park Water Supply [15595]	25-May-12 Heartland Regional Health Authority	Emergency Boil Water Order for Eston Regional Park Water System, located in Heartland Health Region		1	Operational: Does not meet minimum treatment/design requirements Quality: E.coli detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:35 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Eye Hill Creek Outfitters Well [9516]	15-Jun-15 Mamawetan Churchill River Regional Health Authority	Eyehill Creek Outfitters, EBWO, E.coli detected in drinking water system		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system
Fiske Bar and Grill PW (25938)	16-Jan-17 Heartland Regional Health Authority	PDWA Issued Due to Lack of Treatment	1		Operational: Does not meet minimum treatment/design requirements Quality: Suspected contamination
Fitzpatrick Farm Fresh Water (100272)	16-Dec-16 Sun Country Regional Health Authority	PDWA for Fitzpatrick Farm Fresh Well due to high risk well	1		Operational: Does not meet minimum treatment/design requirements Quality:

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:35 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Flotten Lake Resort Distribution System [12322]	15-Sep-13 Prairie North Regional Health Authority	Flotten Lake Resort PDWA - Insufficient treatment	1		Operational: Does not meet minimum treatment/design requirements Quality:
Forrest Lake Lodge [15906]	20-Jun-14 Mamawetan Churchill River Regional Health Authority	Forest Lake Lodge	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system
Foster Lake Lodge - Brunansky [17234]	15-Jun-13 Mamawetan Churchill River Regional Health Authority	Brunansky's Foster Lodge Lodge		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:35 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Foster River Camps [15159]	20-Jun-09 Mamawetan Churchill River Regional Health Authority	EBWO for Foster River Camps due to E.coli		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system
Garden River Outfitting [1161]	21-Nov-17 Prince Albert Parkland Regional Health Authority	PDWA Issued Garden River Outfitting	1		Operational: Does not meet monitoring requirements Quality:
George Lake Camp Outfitting [15654]	10-Jun-06 Mamawetan Churchill River Regional Health Authority	EBWO for George Lake Camp Outfitting due to E.coli		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:35 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Good Spirit Bible Camp - Well [13694] NE 08-29-05 W2	15-Jul-08 Sunrise Regional Health Authority	PDWA Good Spirit Bible Camp Well - issued due to lack of water sampling.	1		Operational: Does not meet monitoring requirements Quality:
Greek Palace [6477]	20-Dec-16 Saskatoon Regional Health Authority	PDWA issued to Greek Palace (#6477) - Follow up by KEC	1		Operational: Undetermined source of contamination Quality: Exceedance of MAC or drinking water standard
Haskins Bay Fly-in [12683]	17-Jun-11 Mamawetan Churchill River Regional Health Authority	PDWA issued on Haskins Bay Fly-in due to total coliforms	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:35 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Hawkrock Wilderness Adventures [15003]	04-Jul-07 Mamawetan Churchill River Regional Health Authority	PDWA for Hawkrock Wilderness Adventure Ltd. due to total coliforms	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system
Hepburn Lake Lodge Ltd. [15597]	21-Jun-13 Mamawetan Churchill River Regional Health Authority	Hepburn Lake Lodge Ltd.		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system
High Rock Lake Lodge [16537]	17-Jun-16 Mamawetan Churchill River Regional Health Authority	High Rock Lake Lodge TWT Ltd. (16537), PDWA, Presence of Total Coliforms	1		Operational: Quality: Total coliforms detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:35 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Hitchcock Hideaway Well [15302]	26-May-17 Heartland Regional Health Authority	PDWA for Hitchcock's Hideaway Public Accommodation	1		Operational: Does not meet minimum treatment/design requirements Quality:
Holt Lake Lodge Adventures [14036]	12-Jun-15 Mamawetan Churchill River Regional Health Authority	Holt Lake Lodge Adventures, EBWO, Insufficient treatment and residuals		1	Operational: Does not meet minimum treatment/design requirements Quality: E.coli detected in drinking water system
Hunter Bay Lodge [15564]	14-Jun-17 Mamawetan Churchill River Regional Health Authority	EBWO, Hunter Bay Lodge, 14jun17, 6 E.coli, >100 Total coliform		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:35 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
HUTTERIAN BRETHREN CHURCH OF WEST BENCH WATERWORKS	11-May-18 Cypress Regional Health Authority	EBWO West Bench Hutterian Colony	1		Operational: Undetermined source of contamination Quality: E.coli detected in drinking water system
Iskwatikan Lake Lodge [15162]	07-Jun-14 Mamawetan Churchill River Regional Health Authority	Iskwatikan Lake Lodge	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system
Jan Lake Convenience Store [1100322]	02-Sep-11 Mamawetan Churchill River Regional Health Authority	Jan Lake Convenience Store		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:35 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Jems Restaurant Well [1000655]	06-Oct-17 Prairie North Regional Health Authority	Jems Restaurant PDWA	1		Operational: Treatment / distribution equipment failure or damage Quality: Unacceptable turbidity or particle counts in treated water
Jims Meats - Water Supply [14858] Jims Meats - food processor	27-Jan-12 Heartland Regional Health Authority	PDWA Jim's Meats - SW 28-38-24W3M in the Rural Municipality of Grass Lake # 381	1		Operational: No or inadequate disinfection at the treatment plant Quality: Total coliforms detected in drinking water system
Johnson River Camp [23361]	07-Jun-10 Mamawetan Churchill River Regional Health Authority	EBWO for Johnson River Camp due to E.coli		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:35 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Jug Bay Sport Fishing [21119]	30-Jul-10 Mamawetan Churchill River Regional Health Authority	EBWO for Jug Bay Sport Fishing due to E.coli		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system
K & C Meats - Well [13779] K & C Meats [13753] - slaughter house	15-Feb-11 Sunrise Regional Health Authority	PDWA Issued for K & C Meats - Well	1		Operational: Does not meet monitoring requirements Quality:
Kamkota Lodge [12726]	31-May-08 Mamawetan Churchill River Regional Health Authority	EBWO for Kamkota Lodge Cabin #2 due to E.coli		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:35 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Kennedy Hotel Well [8392]	23-Sep-13 Sun Country Regional Health Authority	PDWA issued for Kennedy Hotel well due to coliform bacteria	1		Operational: Quality: Total coliforms detected in drinking water system
Kingfisher Lodge [15598]	29-May-06 Mamawetan Churchill River Regional Health Authority	EBWO Kingfisher Lodge 2 EC and 27 TC		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system
Kings Park Speedway Well [16973]	24-May-13 Regina Qu'Appelle Regional Health Authority	PDWA issued for Kings Park Speedway - RM 159	1		Operational: Undetermined source of contamination Quality: Total coliforms detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:35 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Kississing Camps - Kakinagimak Outpost [15503]	21-Jun-13 Mamawetan Churchill River Regional Health Authority	Kississing Lake Lodge - Kakinagimak Lake		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system
Kississing Camps - Nemei Lake Outpost [15719]	17-Jun-16 Mamawetan Churchill River Regional Health Authority	Kississing Camps – Nemei Lake Outpost, EBWO, 1/100mL E.coli, 70/100mL TC, 93/100mL TC		1	Operational: Does not meet minimum treatment/design requirements Quality: E.coli detected in drinking water system
Kississing Camps - Phelan Lake Outpost (15558)	06-Jun-15 Mamawetan Churchill River Regional Health Authority	Kississing Camps Phelan Lake Outpost		1	Operational: No or inadequate disinfection at the treatment plant Quality: E.coli detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:35 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Kississing Camps - Waskwei Lake Outpost (15504)	21-Jun-13 Mamawetan Churchill River Regional Health Authority	Kississing Lake Lodge - Waskwei Lake Outpost	1		Operational: No or inadequate disinfection at the treatment plant Quality: Total coliforms detected in drinking water system
La Fleur Outdoor Adventures [14681]	14-Jul-09 Mamawetan Churchill River Regional Health Authority	EBWO for Lafleur Outdoor Adventures due to E.coli		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system
Lady Lake Regional Park - Well [13511] RM of Preeceville #334	15-Jun-09 Sunrise Regional Health Authority	PDWA for Lady Lake Regional Park - Well RM of Preeceville #333	1		Operational: Quality: Total coliforms detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:35 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Lake Athabasca Lodge [15383]	26-Jun-06 Mamawetan Churchill River Regional Health Authority	EBWO for Lake Athabasca Lodge due to E.coli		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system
Lawrence Bay Lodge - Kamatsi Lake [17119]	30-Jun-07 Mamawetan Churchill River Regional Health Authority	EBWO, Lawrence Bay Lodge - Kamatsi Lake Outpost, 30Jun2007		1	Operational: Does not meet minimum treatment/design requirements Quality: E.coli detected in drinking water system
Lone Wolf Camps [15903]	25-Jun-07 Mamawetan Churchill River Regional Health Authority	EBWO for Lone Wolf Camps due to E.coli		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:35 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Lucien Lake Regional Park [6879]	08-May-18 Saskatoon Regional Health Authority	PDWA for Lucien Lake Regional Park	1		Operational: Does not meet minimum treatment/design requirements Quality: Unacceptable turbidity or particle counts in treated water
Luseland Fairgrounds Well [23333]	02-Jul-10 Heartland Regional Health Authority	PDWA - Luseland Campground	1		Operational: Undetermined source of contamination Quality: Total coliforms detected in drinking water system
M & N Resort Distribution System [9051]	27-Jul-15 Prairie North Regional Health Authority	M & N Resort Precautionary Drinking Water Advisory	1		Operational: Does not meet minimum treatment/design requirements Quality:

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:35 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Macoun Lake Island Lodge [15212]	11-Jun-14 Mamawetan Churchill River Regional Health Authority	Macoun Lake Island Lodge	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system
MacPherson Lake Lodge [14986]	29-May-06 Mamawetan Churchill River Regional Health Authority	EBWO for MacPherson Lake Lodge due to E.coli		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system
Manitou Lake Regional Park Water System [12428]	13-Jun-18 Prairie North Regional Health Authority	PDWA issued on Manitou Lake Regional Park, June 13 2018	1		Operational: Inadequate disinfection residual in distribution system Quality: Unacceptable turbidity or particle counts in treated water

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:35 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Melville Beach Community Well (26237)	04-Jul-12 Sunrise Regional Health Authority	Emergency Boil Water Order (EBWO) for Melville Beach Community Well		1	Operational: Quality: E.coli detected in drinking water system
Milton Lake Lodge [15324]	26-Jun-06 Mamawetan Churchill River Regional Health Authority	EBWO for Milton Lake Lodge due to E.coli		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system
Minor Bay Lodge [15010]	22-Jun-10 Mamawetan Churchill River Regional Health Authority	PDWA for Minor Bay Lodge & Outpost Ltd - Spencer Lake Outpost due to total coliforms	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:36 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Misaw Lake Lodge [15135]	25-Jun-16 Mamawetan Churchill River Regional Health Authority	Misaw Lake Lodge, EBWO, 9 TC/4 E.coli		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system
Missi Lake Lodge [15261]	12-Jun-15 Mamawetan Churchill River Regional Health Authority	Missi Lake Lodge	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system
Morning Lake Outfitters [16118]	14-Jun-07 Mamawetan Churchill River Regional Health Authority	EBWO for Morning Lake Outfitters due to E.coli		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:36 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Nemeiben Lake Campground [15937]	18-May-18 Mamawetan Churchill River Regional Health Authority	PDWA Nemeiben Lake Campground (Lac La Ronge) 18May18	1		Operational: Does not meet minimum treatment/design requirements Quality:
Nemeibien Lake Canoe & Bible Camp [21043]	04-Jul-13 Mamawetan Churchill River Regional Health Authority	Nemeibien Lake Canoe & Bible Camp	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system
Norseman Outfitters [17572]	21-Apr-11 Prince Albert Parkland Regional Health Authority	Norseman Outfitting EBWO due to E.coli		1	Operational: Does not meet reporting requirements Quality: E.coli detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:36 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Northern Reflection Lodge [15265]	22-Jun-10 Mamawetan Churchill River Regional Health Authority	PDWA for Northern Reflection Lodge due to total coliforms	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system
Paull River Wilderness Camp [12523]	17-Jun-09 Mamawetan Churchill River Regional Health Authority	EBWO for Paull River Wilderness Camps due to E.coli		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system
Pawistik Lodge Inc. [12223]	12-Jul-14 Mamawetan Churchill River Regional Health Authority	Pawistik Lodge Inc.	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:36 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Perry's Approved Private Care Home (29322)	20-Sep-17 Regina Qu'Appelle Regional Health Authority	PDWA - Perry's Approved Private Care Home	1		Operational: Undetermined source of contamination Quality: Total coliforms detected in drinking water system
Phil Foster Wilderness Fishing [15819]	25-Jun-07 Mamawetan Churchill River Regional Health Authority	PDWA for Phil Foster Wilderness Fishing due to total coliforms	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system
Pickerel Bay Cabins Ltd. [15268]	11-Jun-10 Mamawetan Churchill River Regional Health Authority	EBWO for Pickerel Bay Cabins Ltd. due to E.coli		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:36 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Pike Lake Prov. Park - Admin Building [4934]	15-Sep-17 Saskatoon Regional Health Authority	PDWA for Pike Lake Provincial Park Admin. Building due to insufficient treatment and turbidity	1		Operational: No or inadequate disinfection at the treatment plant Quality: Unacceptable turbidity or particle counts in treated water
Pilots Lodge [17110]	01-Jul-07 Mamawetan Churchill River Regional Health Authority	EBWO for Pilot's Lodge due to E.coli		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system
Pine Point Lodge & Outpost - Athapapuskow Lake [14162]	08-Jun-07 Mamawetan Churchill River Regional Health Authority	PDWA for Pine Point Lodge & Outpost due to total coliforms	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:36 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Pipestone Lake Lodge [12506]	25-Jun-07 Mamawetan Churchill River Regional Health Authority	PDWA for Pipestone Lake Fishing Lodge Inc. due to total coliforms	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system
Pointer Lake Lodge [12548]	04-Jun-10 Mamawetan Churchill River Regional Health Authority	PDWA for Pointer Lake Lodge due to total coliforms	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system
Prairie Lake Regional Park Water Supply [23306]	28-Jun-12 Heartland Regional Health Authority	EBWO - Prairie Lake Regional Park Water Supply issued due to the presence of E coli		1	Operational: Does not meet minimum treatment/design requirements Quality: E.coli detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:36 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Prill Lake Lodge [15899]	13-Jun-08 Mamawetan Churchill River Regional Health Authority	PDWA for Prill Lake Lodge due to total coliforms	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system
Readlyn Water Co-operative [16221]	30-Jul-09 Five Hills Regional Health Authority	Readlyn Water Co-op PDWA	1		Operational: Does not meet minimum treatment/design requirements Quality: Suspected contamination
Reindeer Lake Lodge (1100258)	02-Jun-17 Mamawetan Churchill River Regional Health Authority	PDWA, Reindeer Lake Lodge, 22june2016, 5 total coliforms present.	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:36 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
RM of Turtle River North Public Well [11313]	18-Jan-17 Prairie North Regional Health Authority	Do Not Drink - RM of Turtle River No. 469 - North Well	1		Operational: Quality: Exceedance of MAC or drinking water standard
Rockin Beach Regional Park Well [11253]	30-Apr-18 Five Hills Regional Health Authority	PDWA Issued to Rockin Beach RP	1		Operational: Start up of waterworks Quality:
Rolling Hills Water Lines Co-operative [16878]	01-Aug-17 Regina Qu'Appelle Regional Health Authority	PDWA- Rolling Hills Water Lines Co-operative	1		Operational: No certified or adequately trained operator as required Quality: Suspected contamination

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:36 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Rural Municipality of Buchanan No. 304 - Well (SE 23-32-4-W2) [13621]	25-Mar-11 Sunrise Regional Health Authority	PDWA for R.M. of Buchanan Well No. 4 (SE-23-32-4 - Est.#13621) replaces EBWO of May 13, 2010	1		Operational: Quality: Total coliforms detected in drinking water system
Rural Municipality of Buchanan No. 304 - Well No. 1(NW 22-30-6 W2M) [13623]	08-May-08 Sunrise Regional Health Authority	PDWA Issued - RM of Buchanan - Well No. 1	1		Operational: Quality: Total coliforms detected in drinking water system
Rural Municipality of Sliding Hills No. 273 - Well No. 1 [13625]	24-Oct-16 Sunrise Regional Health Authority	PDWA - Rural Municipality of Sliding Hills No. 273 - Well No. 1 [13625]	1		Operational: Undetermined source of contamination Quality: Total coliforms detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:36 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Rural Municipality of Sliding Hills No. 273 - Well No. 1 [13625]	07-Oct-10 Sunrise Regional Health Authority	PDWA issued to R.M.#273 - Sliding Hills Community Well#1 (Donwell)	1		Operational: Quality: Total coliforms detected in drinking water system
Saskatoon Livestock Sales [7226]	07-Mar-17 Saskatoon Regional Health Authority	Saskatoon Livestock Sales Ltd PDWA	1		Operational: Does not meet minimum treatment/design requirements Quality: Unacceptable turbidity or particle counts in treated water
Scott Lake Lodge [15144]	13-Jul-10 Mamawetan Churchill River Regional Health Authority	EBWO for Scott Lake Lodge Ltd. due to E. coli		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:36 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Seager Wheeler Farm [6909] Seager Wheeler Farm - well [6909]	29-Jul-16 Saskatoon Regional Health Authority	PDWA Issued to Seager Wheeler Farm (#006909) - Follow up by DL July 29, 2016	1		Operational: Undetermined source of contamination Quality: Total coliforms detected in drinking water system
SHELL LAKE WATERWORKS	16-May-18 Prince Albert Parkland Regional Health Authority	2018-05-16-Shell Lake PDWA	1		Operational: Start up of waterworks Quality:
Shell River Campground [130]	28-Sep-17 Prince Albert Parkland Regional Health Authority	EBWO Issued Spruce River Campground		1	Operational: Does not meet monitoring requirements Quality: E.coli detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:36 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Silence of the North - PW [1100168] Silence of the North [1100168]	18-Jul-16 Mamawetan Churchill River Regional Health Authority	Silence of the North, PDWA, 8 TC	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system
Simpson's Sportman Lodge Well [10259]	03-May-17 Kelsey Trail Regional Health Authority	EBWO - Simpson's Sportsman Lodge - KTHR		1	Operational: Does not meet reporting requirements Quality: E.coli detected in drinking water system
Slim's Cabins - Cameron's Point (27549)	22-Jun-17 Mamawetan Churchill River Regional Health Authority	PDWA issued, Slim's Camps - Cameron Pt. - 31 total coliforms, no disinfection treatment	1		Operational: Does not meet minimum treatment/design requirements Quality: Total coliforms detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:36 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Slim's Cabins - Kamuchawie Lake [13978]	20-Jun-11 Mamawetan Churchill River Regional Health Authority	PDWA Issued at Slim's Cabins Ltd. - Kamuchawie Lake - due to detection of total coliforms	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system
Slim's Cabins - Kipahigan Lake [13956]	10-Jun-11 Mamawetan Churchill River Regional Health Authority	EBWO for Slim's Cabins - Kipahigan Lake due to E.coli		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system
Slim's Cabins - Laurie Lake [13982]	20-Jun-16 Mamawetan Churchill River Regional Health Authority	Slim's Cabins - Laurie Lake, PDWA, >100 Total Coliforms	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:36 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Slim's Cabins - Scotties Beach [13972]	25-Jun-07 Mamawetan Churchill River Regional Health Authority	EBWO for Russell's Churchill River Camp Ltd - Scotties Beach due to E.coli		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system
Slim's Cabins - Tomahawk Lake Outpost [12418]	20-Jun-11 Mamawetan Churchill River Regional Health Authority	EBWO for Slim's Cabins Ltd. - E. coli detected in Tomahawk Lake Outpost drinking water system		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system
South Bay Outfitters [15672]	05-Jun-14 Mamawetan Churchill River Regional Health Authority	South Bay Outfitters		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:36 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
South Ridge Care Home [16204]	22-Jun-18 Prince Albert Parkland Regional Health Authority	EBWO South Ridge Care Home, Christopher Lake		1	Operational: Treatment / distribution equipment failure or damage Quality: E.coli detected in drinking water system
Sportsman's Lodge Ltd. [15272]	27-Jun-17 Mamawetan Churchill River Regional Health Authority	EBWO, Sportsman's Lodge Ltd., 27jun17, 1 e.coli, 1 total coliform		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system
Spring Bay Lodge [15127]	29-Jun-13 Mamawetan Churchill River Regional Health Authority	Spring Bay Lodge		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:36 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Stockman's Lodge [15346]	28-Jun-17 Mamawetan Churchill River Regional Health Authority	PDWA, Stockman's Lodge, 28Jun2017, 16 total coliforms	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system
Strasbourg Bible Camp [14802]	02-Jun-16 Saskatoon Regional Health Authority	Strasbourg Bible Camp - Chlorine pump failed - MS followed up	1		Operational: Inadequate disinfection residual in distribution system Quality:
The Harvest Moon Café - Well (25956)	17-Nov-17 Cypress Regional Health Authority	The Harvest Moon Cafe - Well		1	Operational: Does not meet minimum treatment/design requirements Quality: E.coli detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:36 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
The New Canoe Lake West Resort 1987 [16087]	11-Sep-10 Mamawetan Churchill River Regional Health Authority	PDWA for The New Canoe Lake West Resort 1987 due to total coliforms	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system
Thompson's Camps - Daly Lake Outpost [15576]	16-Jun-10 Mamawetan Churchill River Regional Health Authority	EBWO for Thompson's Camp - Daly Lake Outpost due to E.coli		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system
Thunder Mountain Outfitting [21930]	06-Jun-09 Mamawetan Churchill River Regional Health Authority	EBWO for Thunder Mountain Outfitting due to E.coli		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:36 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Time & Place R.V. Park (26116)	10-May-17 Saskatoon Regional Health Authority	Time & Place RV Park - Elevated turbidity following equipment maintenance	1		Operational: Undetermined source of contamination Quality: Unacceptable turbidity or particle counts in treated water
Tinker's Camp (27816)	21-Jul-14 Mamawetan Churchill River Regional Health Authority	Tinker's Camp	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system
Top of the Rock Adventures [23552]	17-Jun-10 Mamawetan Churchill River Regional Health Authority	PDWA for Top of the Rock Adventures due to total coliforms	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:36 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Triveet Lake Lodge [14975]	16-Jun-17 Mamawetan Churchill River Regional Health Authority	EBWO, Triveet Lake Lodge, 16jun17, 1 E.coli, 75 total coliforms		1	Operational: Does not meet minimum treatment/design requirements Quality: E.coli detected in drinking water system
True North Lodge [17361]	20-Jun-08 Mamawetan Churchill River Regional Health Authority	EBWO issued for True North Lodge [17361]		1	Operational: Quality: E.coli detected in drinking water system
Tuxford Rural Water Supply Pipeline [17308]	06-Jul-09 Five Hills Regional Health Authority	Tuxford Rural Water Pipeline PDWA	1		Operational: Does not meet monitoring requirements Quality:

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:36 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Twin Lake Fly-in [15704]	08-Jun-12 Mamawetan Churchill River Regional Health Authority	Twin Lake Fly-in Ltd.	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system
Two Fingers Fishing Camp (15279)	10-Jun-13 Mamawetan Churchill River Regional Health Authority	Two Fingers Fishing Camp		1	Operational: Inadequate disinfection residual in distribution system Quality: E.coli detected in drinking water system
Ubiquity Lake Outfitters [15879]	25-Jun-07 Mamawetan Churchill River Regional Health Authority	PDWA for Ubiquity Lake Outfitters due to total coliforms	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:36 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Unity Golf Club Well (27367)	08-May-17 Heartland Regional Health Authority	PDWA Issued to Unity Golf Club Well Due to Overgrown Bacteriological Result	1		Operational: Quality: Total coliforms detected in drinking water system
Valley Alliance Church Well [23889]	22-Jun-17 Regina Qu'Appelle Regional Health Authority	Valley Alliance Church Well - PDWA	1		Operational: Undetermined source of contamination Quality: Total coliforms detected in drinking water system
Valley Alliance Church Well [23889]	08-Nov-17 Regina Qu'Appelle Regional Health Authority	PDWA Issued for Valley Alliance Church Well	1		Operational: Undetermined source of contamination Quality: Total coliforms detected in drinking water system

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:36 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Vermilion Lake Outfitters [23585]	08-Jun-12 Mamawetan Churchill River Regional Health Authority	Vermillion Lake Lodge	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system
Verwood Water Inc. [16364]	05-Aug-08 Five Hills Regional Health Authority	Verwood Water Inc PDWA	1		Operational: Inadequate disinfection residual in distribution system Quality: Suspected contamination
Vinnicombe Care Home [7459]	16-Feb-18 Saskatoon Regional Health Authority	PDWA issued to Vinicombe Care Home	1		Operational: Inadequate disinfection residual in distribution system Quality:

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:36 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
VJ's Fishing Lodge Ltd. [12608]	08-Jun-07 Mamawetan Churchill River Regional Health Authority	PDWA for V.J. Fishing Camp due to total coliforms	1		Operational: Inadequate disinfection residual in distribution system Quality: Total coliforms detected in drinking water system
Weis Moore Meats PW (100128)	03-Aug-17 Sun Country Regional Health Authority	PDWA issued for Weis-Moore Meats Well - Total coliforms det	1		Operational: Undetermined source of contamination Quality: Total coliforms detected in drinking water system
Whitewood Auction Services Limited	12-Jun-18 Regina Qu'Appelle Regional Health Authority	PDWA - Whitewood Auction Services Limited	1		Operational: Does not meet monitoring requirements Quality: Suspected contamination

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:36 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
Wingeier's Swiss and German Style Sausage (600638)	05-Apr-17 Saskatoon Regional Health Authority	EBWO for Wingeier's Swiss and German Style Sausage		1	Operational: Undetermined source of contamination Quality: E.coli detected in drinking water system
Wood Mountain Regional Park Well - Kitchen [11260]	30-Apr-18 Five Hills Regional Health Authority	PDWA Issued to Wood Mountain Regional Park	1		Operational: Start up of waterworks Quality:
Wood Mountain Regional Park Well - Showers [11263]	08-Jun-11 Five Hills Regional Health Authority	PDWA Issued for Wood Mountain Regional Park Shower Well	1		Operational: Inadequate disinfection residual in distribution system Quality: Unacceptable turbidity or particle counts in treated water

Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) currently in Effect for Public Water Supplies that are Regulated by the Regional Health Authorities in Saskatchewan

Fri, 22 Jun 2018 19:57:36 CDT

NOTICE: While Regional Health Authorities (RHA) make every effort to post and remove listings of Precautionary Drinking Water Advisories (PDWA) and Emergency Boil Water Orders (EBWO) in a timely manner, from time to time circumstances may arise that prevent timely revisions to this website. In the event consumers require additional information regarding application of a PDWA or EBWO, they are advised to contact their water supplier or RHA. The contact information for RHA's can be found at: <http://www.health.gov.sk.ca/public-health-inspections>.

Public Water Supply	Date Issued and Regional Health Authority	Title	PDWA	EBWO	Comments
York Lake Golf & Country Club Inc. - Well No. 2 [16730]	17-May-11 Sunrise Regional Health Authority	York Lake Golf & Country Club EBWO remains in effect.	1		Operational: Treatment / distribution equipment failure or damage Quality: Suspected contamination
	18-May-18 Mamawetan Churchill River Regional Health Authority	PDWA Nut Point Campground (Lac La Ronge) 18May18	1		Operational: Does not meet minimum treatment/design requirements Quality:
	16-Jun-17 Prairie North Regional Health Authority	Sandy Beach Lake Regional Park Campground PDWA	1		Operational: Does not meet minimum treatment/design requirements Quality: Unacceptable turbidity or particle counts in treated water
Totals:			103	56	
Advisories/Orders Currently in Effect:			159		